



DATE: April 23, 2025

TO: Board of Education

FROM: Kerstin Kramer, Superintendent Chief Learning Officer

SUBJECT: Approve Agreement #25-37-04M with Rex Moore Group, Inc. for 2025 Fire Alarm Panel Upgrade to EST-4

PRESENTED BY: Todd Rivera, Assistant Superintendent Chief Business Officer

ACTION REQUESTED

Approve Agreement #25-37-04M with Rex Moore Group, Inc. for 2025 Fire Alarm Panel Upgrade to EST-4.

BACKGROUND INFORMATION

The current EST-3 system serving the predominance of the building (except for the West Wing) is obsolete and repair parts are no longer available. To maintain the fire alarm serviceability and minimize the impact of a future primary component failure, this fire panel needs to be upgraded to an EST-4.

RESOURCES REQUIRED: \$53,762.00 - General Maintenance Funds

PREPARED BY: Thea Torelli, Administrative Assistant, Maintenance and Operations

Attachment: THS – Rex Moore Group, Inc. #25-37-04M